



CONCRETE THRUST BLOCKING AND THRUST COLLARS FOR WATER LINES SHALL BE INSTALLED AS SHOWN ON THE CITY OF WILMINGTON STANDARD DETAIL SHEETS SD 4-03, SD 4-10, AND SD 4-11





BACKFILLED IN LOOSE 150mm LAYERS COMPACTED TO TOP OF TRENCH USING LOCAL EXCAVATED MATERIAL, IF APPROVED BY THE ENGINEER, OR SELECT MATERIAL ALL MATERIAL SHALL BE FREE OF ROCKS, FOREIGN MATERIAL, AND FROZEN EARTH. COMPACTION SHALL BE TO APPROX. 95% DENSITY IN ACCORDANCE WITH AASHTO T-99 AS MODIFIED BY THE DEPARTMENT OF TRANSPORTATION.

CLASS "C"


(BEDDING FOR P.V.C. PIPE)








AS MODIFIED BY THE DEPARTMENT OF TRANSPORTATION.



RECONNECT EXISTING WATER METER DETAIL



MAXIMUM TRENCH WIDTH AT TOP OF PIPE			
NOMINAL PIPE SIZE (mm)	TRENCH WIDTH (meters)	NOMINAL PIPE SIZE (mm)	TRENCH WIDTH (meters)
102	0.72	508	1.12
152	0.76	610	1.22
203	0.81	762	1.37
254	0.86	914	1.57
305	0.91	1067	1.68
356	0.97	1219	1.83
406	1.02	1400	1.98
457	1.07		